



TOWN OF PLATTSBURGH
WATER AND WASTEWATER DEPARTMENT

151 BANKER ROAD
PLATTSBURGH, NEW YORK 12901-7307
(518) 562-6890
FAX # (518) 563-8198

Michael S. Cashman
Supervisor

Charles Kostyk
Deputy Supervisor

September 2, 2021

To: Honorable Michael S. Cashman
Members of the Town Board

From: Water & Wastewater Department

RE: Water & Wastewater August Report

- Collected all required monthly samples, including resampling of certain Lead and Copper sites due to insufficient amounts of water the first time, and DBP sampling.
- Meters read, and inventoried. Skip reports completed.
- Operation Reports to CCDH.
- Reviews of the monthly Planning Board Meeting regarding upcoming projects.
- There were 145 daily job orders, and 179 locates for DSNY including 8 Emergency.
- There were 3 after hours call outs. One was a scheduled for a new residential water service inspection. The others were, one for a weather related event causing power outages and the third was a low clear well alarm at GPWTP.
- Conducted a fire flow test on Connecticut Road.
- SIU sampling at Saranac Power Partners.
- Excavated a hydrant on Route 9N due to water issues, it was ground water.
- Removed the retired generator from Bluff Point Main station and returned it to the shop.
- Ongoing efforts with the Fleet Management System.
- Removed and cleaned pumps at Tom Miller Road Lift station.
- One Operator traveled to SUNY Morrisville for the Activated Sludge Exam.
- Hydrant sandblasting and painting in the Cumberland Head area.
- Seven Operators attended the NEWWA Backflow Recertification Course.
- NYS vehicle inspections.
- Installed a window and new air conditioning unit at Well 7 Pump House.
- Removed and clean chemical injection quill at GPWTP.
- Excavated a MLV on Route 3 due to water pooling up near the valve. Initially thought the bolts on the bonnet would need to be replaced, however it appears either the mechanical joint or the pipe has a small pinhole.
- Cleaned manholes in Cadyville Sewer District.
- Flushing at Schuyler Falls Storage Tank.
- Made repairs to the Chlorine day tank at CWTP.
- Investigated issues with the transducer at Route 3 Pump Station.

- Repaired leaking Chlorine injection lines at GPWTP.
- Troubleshooting production issues at CWTP. Wells dead heading against Cla-Valve, replaced solenoid valve with one in stock and ordered a replacement.
- Made repairs to LPS force main on Windswept Lane.
- Witness installation, pressure test, disinfection and sampling for commercial project on PARC.
- Pull and clean pumps at Tom Miller Lift Station.
- Witness installation, pressure testing, and disinfection at commercial project off Tom Miller Road.
- Pulled and cleaned pumps at Tom Miller Lift Station.
- Conducted fire flow test in the Idaho/Montana area that was requested for potential development.
- In house and town wide vehicle and equipment maintenance, repairs and inspections.
- Seasonal beautification.