



TOWN OF PLATTSBURGH
WATER AND WASTEWATER DEPARTMENT

151 BANKER ROAD
PLATTSBURGH, NEW YORK 12901-7307
(518) 562-6890
FAX # (518) 563-8198


Michael S. Cashman
Supervisor

Charles Kostyk
Deputy Supervisor

October 5, 2021

To: Honorable Michael S. Cashman
Members of the Town Board

From: Water & Wastewater Department



RE: Water & Wastewater September Report

- Collected all required monthly samples.
- Meters read, and inventoried. Skip reports completed.
- Operation Reports to CCDH.
- Review of the monthly Planning Board Meeting regarding upcoming projects.
- There were 126 daily job orders, and 166 locates for DSNY including 7 Emergency.
- There were 5 after hours call outs. There was a sewer main backup in Cliff Haven, the line was jetted and there was clean up. Repairs were made to the force main on Windswept Lane. We were called to Rand Hill Road to turn the water off at a residence that had a leak in the basement. Responded to a structure fire on Cumberland Head and turned the water service off. We were paged out for an MVA with a fire hydrant on Ampersand Drive.
- Four Asbestos Supervisor/Handlers attended the mandatory Refresher Course.
- Exploratory digs using the vac-truck, for the contractor working at Bluff Point Main Station looking for the force main.
- Training for the sewage grinder at BP Main Station.
- Troubleshooting of the Fluoride up flow saturator at GPWTP. Ordered a replacement solenoid that did not work. Contacted the manufacturer to order a replacement, however there is availability issues. We are currently manually running this injection system during work hours. CCDH has been notified.
- Replaced leaking valve at Tom Miller Road PRV.
- Flushing in Cadyville and on PARC.
- Troubleshooting at Route 3 Lift Station. Periodically there were extended pump run times. Consulted with Emerick Associates. We ordered a replacement transducer/level sensor. This was installed and the station is back to normal.
- Jet sewer main in the Halsey Corners vicinity.
- Repairs were made to the plumbing at Well 7.
- Cleaned out septic tank at Cadyville Beach.

- The City DPW assisted with their Ground Penetrating Radar as they attempted to locate the force main for the contractor at Bluff Point Main Station. This was not successful.
- All attended the Stop the Bleeding Training.
- Generator start up at Bluff Point Main Station.
- Abandoned a second water service on at a parcel on Flanagan Drive at the property owner's request.
- Pull and clean pumps at Tom Miller Lift Station.
- Jet culver for Highway Department on Cumberland Head Road.
- Cold patch over the manhole at the intersection of Military Turnpike and Rugar Street at the request of CC Highway Department.
- Made repairs to the force main on Windswept Lane again.
- Escorted consulting engineers field staff around through the Cliff Haven/Bluff Point sewer system.
- Serviced generators.
- Repaired a leak on a MLV on Route 3.
- Fleet vehicle NYS Inspections.
- Pulled a manhole on Hammond Lane for City DPW visual inspection.
- One operator interviewed for a vacancy in the B&G Department at TOP.
- Met with NYSEG for work being performed in Schuyler Falls.
- Sewer main investigating including televising in Treadwell Mills area.
- Televiser sewer main in Cliff Haven.
- Pull and clean pumps at Church Street Lift Station.
- Made repairs to plumbing for Schuyler Falls booster pump.
- Switch over aeration tanks at CWWTP.
- 2 fleet vehicles to Dannemora Ford for warranty work.
- Pull and clean pumps at Tom Miller Road Lift Station.
- Seasonal beautification.