



**TOWN OF PLATTSBURGH**  
**WATER AND WASTEWATER DEPARTMENT**

151 BANKER ROAD  
PLATTSBURGH, NEW YORK 12901-7307  
(518) 562-6890  
FAX # (518) 563-8198

*Michael S. Cashman*  
Supervisor

*Charles Kostyk*  
Deputy Supervisor

To: Honorable Michael S. Cashman  
Members of the Town Board

From: Water & Wastewater Department

**RE: Water & Wastewater July Report**

- Collected all required monthly samples. Also collected PFOA for Well 7 and DBP for Greater Plattsburgh and the Macey Lane Water District.
- Meters read, and inventoried. Skip reports completed.
- Operation Reports to CCDH.
- Review of the monthly Planning Board Meeting regarding upcoming projects.
- There were 111 daily job orders, and 142 locates for DSNY including 9 Emergency.
- There were 6 afterhours callouts.
  1. There was a scheduled call out for inspection of an 8" commercial water service that crossed Tom Miller Road.
  2. We received a call from a homeowner in the Rand Hill vicinity for a leak on their service line, when we arrived we determined it was actually their neighbor. The service was shut off and the homeowner was arranging for a contractor to make repairs.
  3. We received a call for low wet well at GPWTP. We went in and found Well 7 tripped. It was reset and placed back in service.
  4. We responded to a call from a resident in Champlain Park who stated they had no water. There were no other issues in this area. Upon investigation it was determined that the check valve in the meter pit had failed in the off position.
  5. We were called out for another NYSEG extremely unreliable power issue at GPWTP.
  6. Town of Champlain Water Department called looking for hydrant parts. We collected a variety of O-rings and met them half way.
- We responded to a main break on Nomad Drive and found a valve off the road that had failed, this was the fire service line for the only building on this road. Repairs were made and in a timely fashion so there was no BWO.
- Cleaned the wet well at Route 9 Lift Station near Chamber of Commerce and pulled and cleaned pump number two.
- Cleaned MLV boxes with vac truck.
- Pulled and cleaned pumps at CWWTP.
- Picked up the new replacement starter motor for Well 1.

- Sewer lateral inspection on Melody Lane.
- Flushing Macey Lane and on Cumberland Head.
- Cleaned manholes in Bluff Point.
- Shut off repair on NYS Route 22B.
- Picked up the old pumps from Route 9 Lift station.
- Generator start up meeting at I-87 Lift station.
- Ongoing efforts with the City of Plattsburgh DPW for their water rehabilitation project on PARC.
- Received calls for pressure issues in the Beekmantown Water District. We followed up with hydrant pressure testing and monitored the booster station, all the levels were in the normal operating range.
- We found a hydrant on the old Airport Road entrance had well below normal flows. This was traced back to a main line valve that had been damaged. The valve was excavated and the internal components of the valve were removed. The hydrant is now fully operational. The valve that was rendered useless was no longer critical since the new supply line to this area is in a different location.
- Witnessing of the pressure testing and disinfection of the new water main at May Currier WTP.
- Replaced the bolts on all the remaining valves in the Nomad Drive vicinity.
- Same side residential water tap on Banker Road.
- Troubleshooting of the booster pump station for Beekmantown.
- Jetting of sewer main for the Village of Dannemora.
- Hydrant flushing in Beekmantown.
- Installed a new transformer at CWWTP.
- Startup meeting Bluff Point Main Station.
- Sandblasting, primer and top coat paint hydrants in the Newell, Facticeau, and Melody Lane area.
- Rebuilt Cl2 pump at GPWTP.
- Raise manholes on Kaycee Loop Road for Highway Department paving.
- Shut off water to a private hydrant on Arizona Road for the property owner.
- Picked up and installed a new air conditioner for the Beekmantown Booster Station.
- Flushing on Macey Lane.
- More work with the City of Plattsburgh DPW.
- Raise manholes on Rugar Street, Military Turnpike, and Plaza Blvd for the Highway Department.
- Bailed out the contractor abandoning the services for the former Jock's Lunch in Cadyville.
- Picked up the refurbished Myers Sewage Pump from Emerick Associates.
- Cleaned the Cl2 day tank and clear well at GPWTP.
- Raise manhole on Tom Miller Road.
- Clean manholes on DeGrandpre Way and Feathers Way.
- Meter pit repair on Bell Road.
- In house and town wide vehicle and equipment maintenance and repairs.
- Seasonal beautification.