



**TOWN OF PLATTSBURGH**  
**WATER AND WASTEWATER DEPARTMENT**

151 BANKER ROAD  
PLATTSBURGH, NEW YORK 12901-7307  
(518) 562-6890  
FAX # (518) 563-8198

*Michael S. Cashman*  
*Supervisor*

*Charles Kostyk*  
*Deputy Supervisor*

To: Honorable Michael S. Cashman  
Members of the Town Board

From: Water & Wastewater Department

**RE: Water & Wastewater October Report**

- Collected all required monthly samples.
- Meters read, and inventoried. Skip reports completed.
- Operation Reports to CCDH.
- Review of the monthly Planning Board Meeting regarding upcoming projects.
- There were 186 daily job orders, and 216 locates for DSNY including 8 Emergency.
- There was 2 afterhours callouts.
  1. We responded to an Emergency Underground on Rand Hill Road.
  2. There was a low clear well alarm at GPWTP. Due to a glitch with the power supply both Wells 6 & 7 tripped out. The Wells were reset, sent to waste then reentered into the system.
- Repaired a leak at Tom Miller PRV.
- Continued our efforts sandblasting and repainting hydrants.
- Replaced a fire hydrant that was totaled as a result of a MVA.
- We came in early to make preemptive repairs to two main line valves at the sharp turn on Ampersand Drive nears Sam's Club in an attempt to avoid the traffic.
- We opened the Quarry Road Water Main Extension to supply the north end. We monitored pressures, and flushed hydrants to confirm the operation of the new PRV. After a few days of operating on the Quarry Road supply we reopened the Eddie Drive supply so both feeds are now live.
- Installed a 2" residential tap in Bluff Point.
- Worked with the Town of Beekmantown preparing for them to begin hauling water from Gateway Drive off Spellman Road to their water storage tanks.
- Fire extinguisher checks.
- Tree removal in Champlain Park.
- Met with Emerick for level issues at Bluff Point Main Station.
- Jet culvert pipes on Kimberly Lane.
- Cleaning in pole barn.
- Repaired 7 water service shutoffs.
- Pull and clean number 1 pump at Banker Road Lift Station.

- Highway Department fell a tree for us at the old water plant in Champlain Park and we did clean up and removal.
- Flushing on south end.
- Installed a 1" residential water tap on Davies Lane.
- Installed a ¾" residential water tap on Jefferson Road.
- Replaced the alarm bell and light at CWWTP.
- Dead end flushing.
- Pull and clean pumps at CWWTP.
- Pull and clean pumps at Banker Road Lift Station.
- Preemptive repairs on 2 MLV's on NYS Route 3 and Sorrell Ave.
- Worked with Control Technologies at Church Road Booster Station in Cadyville to get the fire booster pump back online. The expansion tank located at the booster station needs to be replaced.
- Removed two loads from the digester at CWWTP.
- Asphalt restoration.
- Top soil restoration.
- In house and town wide vehicle and equipment maintenance and repairs.